



Lake Ozark Fire Protection District

1767 Bagnell Dam Blvd. Lake Ozark, Missouri 65049

Phn# 573-365-3380

Fax# 573-365-3758

Pyrotechnic Fireworks Display Requirements

The following application shall be made not less than 14 days prior to the scheduled date of the display. All displays and materials shall be in accordance with Chapter 33 of the International Fire Code as adopted. This paperwork in no way constitutes other local jurisdiction's approval.

Location of Display: _____

Dates and Times of Display: _____

Contact Person in Charge-Phone number: _____

Contracted by City/County Government. If so Contact Name: _____

*Fireworks display operations shall be under the direct supervision of a pyrotechnic operator who is on-site at all times and responsible for all aspects of the related display. Provide the names, addresses, and telephone numbers of all operators including ATF licenses and State of Missouri licenses. Proof of identification may be required.

*The permittee shall furnish a current bond or certificate of insurance.

*Provide an accurate diagram of the grounds on which the display is to be held showing the point at which the fireworks are to be discharged; the location of buildings and occupancy type, highways and other lines of communication, the lines behind which the audience will be restrained, and the location of nearby trees, telegraph or telephone lines and other overhead obstructions. Show the proper location of all storage of fireworks and related materials. The designated landing area shall not be within 100 feet of tents, canopies and membrane structures; shall be an approved large, clear, open area; and shall not allow spectators, vehicles, and/or combustible materials. 50 foot trajectory clearance (minimum) is required.

*Provide a complete list including Class, quantities, and diameter of all fireworks and related materials to be used on-site: _____

*Provide fireworks distributor name, location, and phone number:

*Mortar use shall be in accordance with Chapter 33. State the type(s) of ignition source(s): _____

*A \$100 fee is required if not City/County Government contracted display.

*Storage of fireworks and related materials shall be in approved location and container. List type and location of such:

*Display Discontinued: If the chief or his designee determines a lack of crowd control or the crowd is in danger, or Chapter 33 is not being followed, or any time high winds or bad weather creates a danger, the display shall be postponed until weather conditions are acceptable to the chief or his designee.

*Smoking and open flame use is not allowed with the exception of approved ignition devices for that sole purpose.

*Range Inspections: The entire firing range shall be inspected immediately following a display and prior to allowing public access for the purpose of location unexploded aerial shells. Such shells shall not be handled within 15 minutes of their firing, then doused with water, allowed to stand for not less than 5 minutes and placed in a bucket of water. All materials, used and unused, shall be cleaned up from the site the same day as display.

*If shoot is on the water a permit from the U.S Coast Guard and the Missouri State Water Patrol is also required to be submitted to this office before the deadline.

IF ALL INFORMATION IS NOT RECEIVED PRIOR TO THE 14 DAY DEADLINE THE PERMIT WILL NOT BE ISSUED!

LOFPD Approval: _____ Permittee: _____

Date: _____
